

SECTION A: TO BE COMPLETED BY APPLICANT

Laguna Beach Fire Department

505 Forest Ave., Laguna Beach, CA 92651 (949) 497-0700

HYDRANT FLOW REPORT AND FIRE FLOW INFORMATION

Please complete Sections A and B of this form and submit it to the water purveyor. A copy of this report shall be submitted with construction plans to the Laguna Beach Fire Department.

(This report is valid for 180 days from the test date)

NOTE: Water Purveyors require a fee to be paid prior to completing Section C. Please contact them for payment information.

Date of Request:	Construction Type:	Square Footage*:	
Contact Name:	Project Ad	dress:	
Data Requested for: Fire F	Protection System Design**	Fire Hydrant Flow Report (Check which apply))
*Square Footage must include all attached garages, carports, and solid roof patio covers.			
**Include estimated water (Fire Flow) needed for System Design:GPM			
SECTION B: TO BE COMPLETED BY APPLICANT			
As required by Appendix B of the	2022 CFC, the minimum Hydrant	Flow is:GPM forhours at a	
minimum residual pressure of 20		Title of Applicant	
Water Purveyor ☐ LBCW	′D □ SCWD		
SECTION C: TO BE COMPLET	TED BY THE WATER PURVEYOR		
The test shall be provided from the closest junction node on the same pressure system as the proposed project. NOTE: All water information is provided using the water purveyors' current hydraulic water model simulated under maximum day demand conditions. The pressure provided is reflected at street-level elevations unless noted otherwise. Fire Flow Requested in Section A:GPM Static Press.:PSI Residual Press.:PSI.			
Hydrant Flow Required by Section B:GPM at 20 PSI residual pressure.			
Junction Node location and elevation:			
Elevation of water meter for proje	ect:		
Completed by:Name and T	Fitle of Water Purveyor Representa	Date:ative	—