

Type of Charging Station(s)

Code Compliance Checklist ELECTRIC VEHICLE (EV) CHARGING

Power Levels (proposed circuit rating)

Check one

Eligibility Checklist for Expedited Electric Vehicle Charging Station Permit:

Multi-Family Dwellings

Level 1	110/120 volt alternating current (VAC) at 15 or 20 Amps	i		
Level 2 - 3.3 kilowatt (kW) (low)	208/240 VAC at 20 or 30 Amps			
Level 2 – 6.6kW (medium)	208/240 VAC at 40 Amps	1	 	
Level 2 – 9.6kW (high)	208/240 VAC at 50 Amps	+		
, ,	·			
Level 2 – 19.2kW (highest)	208/240 VAC at 100 Amps			
Other (provide detail):	Provide rating:			
Permit Application Requirements	»:			
A. Does the application include EV	CS manufacturer's specs and installation guidelines?	TY		N
Electrical Load Calculation Work	shoot:			
Electrical Load Calculation Work	Sileet.			
A. Is an electrical load calculation	worksheet included? (CEC 220)		7 [1
B. Based on the load calculation v required?	vorksheet, is a new electrical service panel upgrade	□ <i>)</i>	/ _[
	the electrical service panel upgrade?		7 -	<u> </u>
	ately sized for a continuous load of 125%?	٦ ا	7	7
	d is a Level 2 – 9.6 kW station with a circuit rating of 50 I circuit card with electrical calculations included with the		, [] l
Site Plan and Single Line Drawin	g:			
A. Is a site plan and separate election the permit application?	trical plan with a single-line diagram included with	□ _Y		N
	uirements are triggered for indoor venting (B)), is a mechanical plan included with the	□Y		N
B. Is the site plan fully dimensione	d and drawn to scale?	□Y		N
1) Showing location, size, and		∐Y		Ν
2) Showing location of electric		ĽΥ	-	Ν
3) Showing type of charging sv	votem and mounting		1 1 1	N

Compliance with the California Electrical Code:

Δ Do	es the plan include EVCS manufacturer's specs and installation guidelines?		1 🗆 1
	es the electrical plan identify the amperage and location of existing electrical	 	₩'
se	ervice panel?	ПΥ	
	If yes, does the existing panel schedule show room for additional breakers?	H Y	
	the charging unit rated more than 60 amps or more than 150V to ground? If yes, are disconnecting means provided in a readily accessible location in line of site? (CEC 625.43)		
(N	es the charging equipment have a Nationally Recognized Testing Laboratory IRTL) approved listing mark? (UL 2202/UL 2200)	ПΥ	
	renching is required, is the trenching detail called out?		
1)	Is the trenching in compliance with minimum cover requirements for wiring methods or circuits? (18" for direct burial per CEC 300.5)	ПΥ	
Compl	iance with California Green Building Standards Code:		
A. Do	the CAL Green EV Readiness installation requirements apply to this project:	□Y	
1)	Do the plans demonstrate conformance with mandatory measures for 10% of total parking spaces, for new multifamily dwellings provided for all types of parking facilities, to be electric vehicle charging spaces (EV spaces) capable of supporting future EVCS? (4.106.4.2)	ΠY	
2)	Do the construction documents indicate the location of the proposed EV spaces where at least one is located in common use areas and available to all residents for use? (4.106.4.2.1) Calculations for the required number of EV spaces shall be rounded up to the nearest whole number.	ΠY	
3)	When EV chargers are installed, EV spaces required by Section 4.106.4.2.2 , item shall comply with at least one of the following options: a. The EV space shall be located adjacent to an accessible parking space that complies with CBC Chapter 11A , to allow use of the EV charger from the accessible parking space. b. The EV space shall be located on an accessible route, as defined by CBC Chapter 2, to the building. c. EV charging space(s) comply with Section 4.106.4.2.2 , items 1, 2 and 3 .	Y	
p ^l th sı	his criteria is intended for an expedited EVCS permitting process. If any items are lease revise plans to fit within the eligibility checklist; otherwise the permit applications to fit within the eligibility checklist; otherwise the permit applications or commences. It is a process to the standard plan review and approval process. Plan review commences submittal with up to 3 business days for qualifying expedited projects and up to 10 bus all other EVCS projects.	cation m the day	nay g / afte
	lectrical plans shall be completed, stamped and signed by a California Licensed Elera C-10 electrical contractor.	ctrical E	ngin
la	VCS project review is limited to health and safety requirements found under local, staw. EVCS permit approval is not subject to approval of an association (as defined in le Civil Code).		
oject A	ddress:		
plicant	t Signature:		
	ts Printed Name:		
12			
ntracto	or's License Number and type:		